

Hyde Park - Val-Kill
Swimming Pool

Hosbrouck Company N.Y.

Pool as designed

7130⁰⁰

Alternate design filter
and pumping from stream

6500⁰⁰ ✓

(600) ✓

7100

I think the use of brook water is excellent -
But it is not necessary to fill pool in
12 hours or even 24 hours as it will be
changed only once or twice in summer.

Therefore a smaller motor & pipe may save
money

Try to get the estimate down to 6,000
by further study of drawings.

JWR